

Certificate of Acknowledgment

NORMAN NOBLE, INC.

ISO Class 7

Gown Room

Has been tested in accordance with the specifications and guidelines referenced in ISO 14644-1:2015(E), ISO 14644-3:2005(E), TEST-RP-CC006.3. This certificate does not imply full compliance to any or all of the standards listed herein as there are disciplines exceeding the scope of testing provided by Clean Air Testing, Inc. All details are outlined in the corresponding test report #2104A11

Airborne Non-Viable Particle Measurement

Pass

Airflow Measurement

Pass

Room Pressurization Measurement

Pass

HEPA Filter Installation Leak Test

N/A

Airborne Viable Particle Measurement

N/A

Bacterial Fungal

Surface Viable Particle Measurement

N/A

Bacterial Fungal

Julie Sickinger

4/14/2021



Quality Testing Services by Quality People

37709 Schoolcraft Road, Livonia, MI 48150
ph: (734) 522-1533 • fx: (734) 522-1534
catestinginc.com • info@catestinginc.com

Certificate of Acknowledgment

NORMAN NOBLE, INC.

ISO Class 7

Walk-in Pass Thru

Has been tested in accordance with the specifications and guidelines referenced in ISO 14644-1:2015(E), ISO 14644-3:2005(E), TEST-RP-CC006.3. This certificate does not imply full compliance to any or all of the standards listed herein as there are disciplines exceeding the scope of testing provided by Clean Air Testing, Inc. All details are outlined in the corresponding test report #2104A11

Airborne Non-Viable Particle Measurement

Pass

Airflow Measurement

Pass

Room Pressurization Measurement

Pass

HEPA Filter Installation Leak Test

N/A

Airborne Viable Particle Measurement

N/A

Bacterial Fungal

Surface Viable Particle Measurement

N/A

Bacterial Fungal

Julie Sickinger

4/14/2021



Quality Testing Services by Quality People

37709 Schoolcraft Road, Livonia, MI 48150
ph: (734) 522-1533 • fx: (734) 522-1534
catestinginc.com • info@catestinginc.com

Certificate of Acknowledgment

NORMAN NOBLE, INC.

ISO Class 7

Cleanroom

Has been tested in accordance with the specifications and guidelines referenced in ISO 14644-1:2015(E), ISO 14644-3:2005(E), TEST-RP-CC006.3. This certificate does not imply full compliance to any or all of the standards listed herein as there are disciplines exceeding the scope of testing provided by Clean Air Testing, Inc. All details are outlined in the corresponding test report #2104A11

Airborne Non-Viable Particle Measurement

Pass

Airflow Measurement

Pass

Room Pressurization Measurement

Pass

HEPA Filter Installation Leak Test

N/A

Airborne Viable Particle Measurement

N/A

Bacterial Fungal

Surface Viable Particle Measurement

N/A

Bacterial Fungal

Julie Sickinger

4/14/2021



Quality Testing Services by Quality People

37709 Schoolcraft Road, Livonia, MI 48150
ph: (734) 522-1533 • fx: (734) 522-1534
catestinginc.com • info@catestinginc.com